

# Use of Treated Effluent from the Lower Molonglo Water Quality Control Centre

ACT Health supports the use of treated effluent from the Lower Molonglo Water Quality Control Centre (LMWQCC), provided public health risks associated with the use are understood and minimised.

ACT Health has developed this document to safeguard the public and assist businesses when using treated effluent from the LMWQCC.

## Public Health Risks

Treated effluent has the potential to contain organisms that may compromise public health. Cryptosporidium and Giardia cysts, for example, may not be completely removed by chlorination. Infection by either of these organisms may produce symptoms such as diarrhoea, abdominal cramps, fatigue, nausea, vomiting and fever.

## Uses for Lower Molonglo effluent

Treated effluent may be used for a variety of purposes, in areas where public access can be restricted. Such activities include:

- Construction sites (e.g. concrete batching, dust suppression and vehicle wash down)
- Irrigation of access controlled public sites
- Golf courses (e.g. irrigation, water hazards etc)
- Irrigation of commercial turf
- Drip irrigation of non-food crops
- Water features with disinfection
- Commercial landscaping

It is not considered appropriate to use treated effluent:

- At domestic properties (without additional treatment)
- For irrigation of foods that may be consumed uncooked
- In swimming pools and spa water
- In water features without disinfection
- For any application at childcare and aged care facilities

The treated effluent must not be used for drinking purposes or direct human contact.

INFORMATION

## Storage of treated effluent

Storage of treated effluent for long periods is not recommended because of the high nutrient levels, potential for growth of pathogenic microorganisms such as Legionella and odour control. If the treated effluent is to be stored it should be chlorinated to maintain a minimum of 1.0 mg/litre free chlorine. Signage must be provided stating it is not potable water in accordance with Australian Standard 1319 – 1994, Safety Signs for the Occupational Environment.

## Transportation of treated effluent

Transportation of treated effluent should be in appropriate water carting vehicles that are labelled accordingly. Treated effluent should not be transported in potable water containers.

## Using treated effluent

When using treated effluent, health risks can be minimised by:

- Not producing aerosols when distributing the effluent
- Not allowing the effluent to pool
- Maintaining a free chlorine level of 1.0 mg/litre in water features
- Appropriate signage placed where human contact may occur in accordance with Australian Standard 1319 – 1994, Safety Signs for the Occupational Environment
- Not irrigating food plants that are consumed uncooked
- Ensuring that the effluent does not leave the site

## Public Health Act 1997

The use of treated effluent has the potential to increase risks to public health. The Public Health Act 1997 (The Act) requires that users of treated effluent do not create an insanitary condition.

## Further Advice

For further information or advice regarding use of treated effluent contact:

Health Protection Service

Phone: 6205 1700

Fax: 6205 1705

Website: [www.health.act.gov.au/hps](http://www.health.act.gov.au/hps)

ACTEW Water

Phone: 6248 3111

Fax: 6242 1459

Website: [www.actew.com.au](http://www.actew.com.au)

### Accessibility

The ACT Government is committed to making its information, services, events and venues as accessible as possible.

If you have difficulty reading a standard printed document and would like to receive this publication in an alternative format such as large print, please phone 13 22 81 or email [HealthACT@act.gov.au](mailto:HealthACT@act.gov.au)

If English is not your first language and you require the Translating and Interpreting Service (TIS), please call 13 14 50.

If you are Deaf, or have a speech or hearing impairment and need the teletypewriter service, please phone 13 36 77 and ask for 13 22 81.

For speak and listen users, please phone 1300 555 727 and ask for 13 22 81. For more information on these services visit <http://www.relayservice.com.au>

© Australian Capital Territory, Canberra, July 2014

This work is copyright. Apart from any use as permitted under the *Copyright Act 1968*, no part may be reproduced by any process without written permission from the Territory Records Office, Community and Infrastructure Services, Territory and Municipal Services, ACT Government, GPO Box 158, Canberra City ACT 2601.

Enquiries about this publication should be directed to ACT Health Communications and Marketing Unit, GPO Box 825 Canberra City ACT 2601 or email: [HealthACT@act.gov.au](mailto:HealthACT@act.gov.au)

[www.health.act.gov.au](http://www.health.act.gov.au) | [www.act.gov.au](http://www.act.gov.au)

Enquiries: Canberra 13ACT1 or 132281

HPS-00-0623